

2.2 DG Sets:-

There is 1 DG set in Institute campus . Detailed of the DG Sets are given table....:

Table 2.3 Technical Specifications for DG sets

Sr. No.	Parameter	Technical Specification DG-01
1	Make	Trident Powercraft Pvt. Ltd
2	Capacity	125 KVA
3	Rated Voltage	415 V
4	Full load current	173.9 A
5	Frequency	50 Hz
6	Power factor	0.80
7	RPM	1500
8	Phase	3

